



**IBACOS**

**HOME TO INNOVATION**

**DUCT DESIGNS IN LOW LOAD HOUSES:  
CHALLENGES AND SOLUTIONS  
LESSONS LEARNED FROM BUILDING AMERICA**

**RESNET 2007**

**February 19, 2007**

**Duncan Prah, RA and  
Anthony Stamatopoulos**

- ***Challenges with Low Load Houses  
(Energy Star and the universe beyond it)***
- ***Comfort – what is it and why is it  
important?***
- ***Process Issues***
- ***Advanced Thermal Enclosure Mechanical  
Systems***
  - *Loads*
  - *Equipment*
  - *Ducts*
  - *Supply outlets*

- ***More efficient enclosure***
- ***Lower and lower heating and cooling loads***
- ***Higher latent to sensible load ratios (especially in south)***
- ***More emphasis on “Right Sizing”***



- ***Buy a Flux Capacitor and go back to the 50's***
- ***Get out of the business***
- ***Blame it on someone else***
- ***Rethink how the space conditioning system is designed and installed***
- ***Process needs to change***



- ***Energy Efficiency ≠ Comfort***
- ***Builders typically have more comfort complaints than high bill complaints***
- ***If it ain't comfortable, energy efficiency will be set back 20 years (maybe we don't need a Flux Capacitor...)***
- ***Need to understand comfort fundamentals***

# ***Thermal Comfort Criteria – ASHRAE Std 55***

## ***Items that determine human thermal comfort***

1. **Metabolic Rate**
2. **Clothing Insulation**
3. **Air Temperature**
4. **Mean Radiant Temperature (MRT)**
5. **Air Speed**
6. **Humidity**








- **Cold floor - Hot head**
  - *stratification*
- **Air blowing on person**
  - *poor supply outlet location, selection, temperature, or throw*
- **Cold or Hot Surfaces = Low / High MRT**
  - *poor choice of thermal enclosure elements*
- **Floor to floor or room to room temperature variations**
  - *beyond +/- 2°F = poor design of distribution system, high variance in thermal characteristics of various rooms*

**Predicted % Dissatisfied as a Function of Predicted Mean Vote**










*Up to 20% are dissatisfied because they are too cold*

*A different 10% are dissatisfied because they are too hot*





***If all rooms within a home are within the thermal comfort zone, up to 30% of individuals may be uncomfortable in every room.***






- ***Set performance goals and responsibilities***
- ***What is acceptable and what is not?***
- ***What is the energy and system performance criteria?***
- ***What are the aesthetic criteria?***
- ***Determine expectations - builder, trades, manufacturers, consumer***
- ***What is the process for accountability***
- ***Testing and verification process  
(Commissioning)***



# IBACOS

## INTEGRATED DESIGN PROCESS MAP




## Product Design Process

MKTG / ARCH FLOW

ARCHITECTURE FLOW

MARKETING



- *Delivers or removes energy from space (heats or cools)*
- *Mixes air in room to maintain temperature and fresh air uniformity*
- *Maintains humidity levels in comfort zone*
- *Is unnoticed by the occupants*
- *Is energy efficient*



	System size sf/ton	Air flow cfm/sf	Air exchange rate ACH nat
Historic “Rule of Thumb”	<b>400</b>	<b>1.0</b>	<b>0.5 - 0.75</b>
Energy Star – Cold Climate	<b>1107</b>	<b>0.35</b>	<b>0.31</b>
Energy Star – Mixed Humid Climate	<b>1124</b>	<b>0.34</b>	<b>0.34</b>
40% BA – Cold Climate	<b>1476</b>	<b>0.26</b>	<b>0.10</b>
40% BA – Mixed Humid Climate	<b>1311</b>	<b>0.27</b>	<b>0.19</b>

- ***Lower loads, lower airflow (cfm) per room***
- ***Lower airflow = less air available to mix for the same volume room***
- ***Same size house, same length ducts, lower airflow, duct tightness critical***
- ***Long runs, less airflow, takes time to heat up duct mass, lower outlet temperatures at long runs on short cycles***
- ***Register selection is critical***

	<b>Building America 40%</b>	<b>Energy Star Specs</b>
<b>Foundation</b>	<b>R-18 Basement &amp; Crawlspace walls</b>	<b>R-10 Basement &amp; Crawlspace walls</b>
<b>Above Grade Walls</b>	<b>R-21 - Exterior Sheathing R-5</b>	<b>R-18</b>
<b>Floors Over Unconditioned Space</b>	<b>R-46</b>	<b>R-21</b>
<b>Roof Insulation R-Value</b>	<b>R-54 &amp; Vaulted Ceilings @ R-40</b>	<b>R-38</b>
<b>Windows</b>	<b>U-value 0.30 &amp; SHGC 0.30</b>	<b>U-value 0.35 &amp; SHGC 0.60</b>
<b>Exterior Doors</b>	<b>U-value 0.20</b>	<b>U-value 0.50</b>
<b>Building Air tightness</b>	<b>ACH nat 0.10</b>	<b>ACH nat 0.31</b>
<b>Mechanical Ventilation</b>	<b>HRV: supply 84 cfm, exhaust 84 cfm, run-time 50%, power 100 watts, &amp; efficiency 82%</b>	<b>84 cfm Fresh air intake only</b>
<b>Furnace</b>	<b>94.1 AFUE</b>	<b>92.1 AFUE</b>
<b>AC</b>	<b>18.1 SEER</b>	<b>13.0 SEER</b>

	Building America 40%	Energy Star Specs
Foundation	Slab-on-grade no insulation	Slab-on-grade no insulation
Above Grade Walls	R-13 – Cavity, R-5 Sheathing	R-13
Floors Over Unconditioned Space	N/A	N/A
Roof Insulation R-Value	R-29 Unvented attic	R-30 Unvented attic
Windows	U-value 0.38 & SHGC 0.35	U-value 0.65 & SHGC 0.50
Exterior Doors	U-value 0.20	U-value 0.50
Building Air tightness	ACH nat 0.19	ACH nat 0.34
Mechanical Ventilation	ERV: supply 60 cfm, exhaust 60 cfm, run-time 50%, power 90 watts, & efficiency 80%	60 cfm Fresh air intake only
Heat Pump	9.3 HSPF	7.7 HSPF
AC	18.6 SEER	13.5 SEER

<b>Boulder, CO</b>		<b>Columbus GA</b>	
<b>DB (°F)</b>	<b>Total Hrs</b>	<b>DB (°F)</b>	<b>Total Hrs</b>
<b>90 to 100</b>	<b>118</b>	<b>90 to 98</b>	<b>155</b>
<b>78 to 90</b>	<b>673</b>	<b>78 to 90</b>	<b>1532</b>
<b>32 to 68</b>	<b>5307</b>	<b>32 to 68</b>	<b>3911</b>
<b>2 to 32</b>	<b>1610</b>	<b>14 to 32</b>	<b>181</b>
<b>-10 to 2</b>	<b>77</b>		

		Building America 40%		Energy Star	
	Area (ft <sup>2</sup> )	Htg load (Btuh)	Clg load (Btuh)	Htg load (Btuh)	Clg load (Btuh)
First Floor & Basement	3,492	26,112	21,554	42,436	33,397
Upper Bedrooms	936	8,928	6,387	13,004	10,367
Entire House	4,428	35,040	25,423	55,440	38,952
Other equip loads		2,007	558	5,017	1,139
Equip. @ 0.98 RSM			25,409		39,209
Latent cooling			0		0
<b>TOTALS</b>	<b>4,428</b>	<b>37,047</b>	<b>25,409</b>	<b>60,457</b>	<b>39,209</b>

Outdoor Design Temps: -3°F & 93°F,  
Indoor Design Temps 71 & 76



		Building America 40%		Energy Star	
	Area (ft <sup>2</sup> )	Htg load (Btuh)	Clg load (Btuh)	Htg load (Btuh)	Clg load (Btuh)
First Floor & Basement	3,492	13,762	20,686	22,365	31,911
Upper Bedrooms	936	4,705	6,049	6,853	9,887
Entire House	4,428	18,467	24,217	29,218	36,985
Other equip loads		1,058	482	2,644	949
Equip. @ 0.98 RSM			23,464		36,038
Latent cooling			0		0
<b>TOTALS</b>	<b>4,428</b>	<b>19,525</b>	<b>23,464</b>	<b>31,862</b>	<b>36,038</b>

Outdoor Design Temps: 32 °F & 90°F  
Indoor Design Temps 71°F & 76°F

# COLD CLIMATE HOUSE PEAK AIRFLOW (CFM)

		Building America 40%		Energy Star	
	Area (ft <sup>2</sup> )	Htg AVF (cfm)	Clg AVF (cfm)	Htg AVF (cfm)	Clg AVF (cfm)
Entry	212	31	25	50	43
Dining	168	70	100	93	159
Pantry	36	8	3	13	4
Powder	36	0	2	0	2
Master Bathroom	174	35	58	48	74
Master Bedroom	306	130	223	158	294
Kitchen / Nook	300	71	127	95	172
Laundry	68	32	19	37	27
Family	304	84	145	103	156
Bedroom	225	83	80	118	83

Outdoor Design Temps: -3°F & 93°F,  
Indoor Design Temps 71 & 76

Peak		Building America 40%			Energy Star	
	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)		Htg load (Btuh)	Clg load (Btuh)
Entire House	3,934	27,730	22,880		4,8015	34,307
Other equip loads		1,107	535		2,362	923
Equip. @ 0.95 RSM			22,993			34,596
Latent cooling			4,134			6,890
TOTALS	3,934	28,838	27,128		50,377	41,486

Outdoor Design Temps: 27°F & 93°F  
Indoor Design Temps 71°F & 76°F

		Building America 40%		Energy Star	
	Area (ft <sup>2</sup> )	Htg load (Btuh)	Clg load (Btuh)	Htg load (Btuh)	Clg load (Btuh)
Entire House	3,934	24,579	21,678	42,559	31,630
Other equip loads		981	455	2,093	751
Equip. @ 0.95 RSM			21,026		30,763
Latent cooling			4,555		7,705
<b>TOTALS</b>	<b>3,934</b>	<b>25,561</b>	<b>25,581</b>	<b>44,652</b>	<b>38,467</b>


Outdoor Design Temps: 32°F & 90°F  
Indoor Design Temps 71°F & 76°F

# MIXED HUMID HOUSE PEAK AIRFLOW (CFM)

		Building America 40%		Energy Star	
	Area (ft <sup>2</sup> )	Htg AVF (cfm)	Clg AVF (cfm)	Htg AVF (cfm)	Clg AVF (cfm)
Laundry	63	91	121	81	95
Office	150	95	158	119	166
Mstr Bed	265	186	164	198	176
Mstr Bath	182	90	77	64	75
Bedroom 2	195	166	111	139	101
Bedroom 3	209	132	130	217	175
Family-Dining	650	277	404	400	448

Outdoor Design Temps: 27°F & 93°F  
Indoor Design Temps 71°F & 76°F

- *Fan cycling unit incorporated into simple T-stat.*
- *Master – With Remote Slave(s)*
- *Maybe back to two systems....*







- ***Advanced Thermal Enclosure Mechanical Systems***
  - *Loads & cfm (done)*
  - *Equipment*
  - *Ducts*
  - *Supply outlets*

- ***Single Speed Challenges***
  - Poor dehumidification
  - Room to room temperature differences
  - Longest duct run may not heat up or cool down
  - Zoning and matching part load performance
- ***Multi-Speed Benefits***
  - Part load performance
  - Assists in meeting heating and cooling flow variations
  - Can accommodate combinations of flow and resistance

<u>DEVICE</u>	<u>PRESSURE DROP</u>
Standard Filter	.10 Clean
High Efficiency Filter	.20 Clean
Humidifiers/Electric Heaters	.10 to .20
Supply Outlet	.03
Return Grille	.03
Balancing Damper	.03 Open
Coil	.15 to .45 wet coil
Duct System	.....



<u>DEVICE</u>	<u>PRESSURE DROP</u>
Supply Register	.03
Return Grille	.03
Balancing Damper	.03
Coil	<u>.33 wet coil</u>
Total EXCLUDING DUCTS	<b>.42</b>

## AIR DELIVERY—CFM (With Filter)\*

UNIT SIZE CARRIER	RETURN-AIR SUPPLY	SPEED	EXTERNAL STATIC PRESSURE (In. wc)							
			0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8
060-12	1 side or bottom	High	1490	1450	1400	1345	1275	1190	1080	960
		Med-High	1190	1180	1155	1120	1070	1005	915	810
		Med	1015	1010	995	965	920	875	800	715
		Med-Low	870	860	840	820	780	735	670	580
		Low	685	670	645	620	585	545	495	420
080-12	1 side or bottom	High	1605	1560	1510	1450	1380	1300	1195	1045
		Med-High	1305	1290	1265	1225	1175	1100	995	895
		Med	1135	1125	1110	1080	1030	965	885	800
		Med-Low	990	980	965	930	880	825	760	685
		Low	805	780	745	700	660	630	575	495
		High	1810	1755	1690	1640	1565	1495	1410	1330
		Med-High	1420	1385	1350	1305	1260	1210	1145	1090

**0.55 IWC at 1200 cfm**

For 1200 cfm System

External System Pressure Drop = 0.55 IWC

Equipment Pressure Gain -0.42 IWC (for Devices)

---

What's left for the duct system? = 0.13 IWC ASP

For 1200 cfm System

External System Pressure Drop = 0.50 IWC

Equipment Pressure Gain -0.42 IWC (for Devices)

---

What's left for the duct system? = 0.08 IWC ASP




- ***Duct Design – Critical Factors***
  - *Assume Tight Ducts*
  - *Available Static Pressure & CFM*
  - *Determine Equivalent Lengths*
  - *Design using “Variable Friction” (Combination of Static Regain & Constant Velocity)*
  - *Iterate Design (Duct sizes & Routing)*



IBACOS


# DUCT SIZING PROCEDURE





# IBACOS


## BA 40% COLD CLIMATE





# IBACOS


## BA 40% COLD CLIMATE





# IBACOS

## 40% BA MIXED HUMID








- **Static Regain and Constant Velocity**
  - Every duct run in the system needs to be calculated
  - Maintain constant static pressure throughout the air distribution system
  - Design to ensure constant air velocity in trunk and branches.
    - If you loose velocity, can't get it back
  - Ensure volume *and* velocity at supply outlets
  - (ASHRAE HVAC and Fundamentals Handbooks)






# IBACOS

## SUPPLY AIR TEMPERATURE



- **Compact vs. perimeter distribution**
- **High mass vs. low mass**


- **Terminal outlet temperature**
- **Less margin for error**





# IBACOS


## TERMINAL AIR TEMPERATURE LOW MASS, COMPACT SYSTEM





IBACOS

# TERMINAL AIR TEMPERATURE HIGH MASS, PERIMETER SYSTEM






- ***Once again – Peak vs. Part Load***
- ***Throw***
- ***Face Velocity***
- ***Terminal Velocity***
- ***Air volume (cfm)***
- ***Pressure drop***
- ***Noise***
- ***Location, Location, Location***

## Register Selection Criteria

- *Throw*
- *Pressure Drop*
- *Noise*



Floor Register Performance (10x4)



## 1. Calculate adjustment

CFM	80
Ak	0.118
K	3.3
Vt	75
Throw	9
Adjustment	0.777

## 2. Enter design parameters

CFM	48
K	3.3
<b>Terminal Velocity</b>	<b>Throw (feet)</b>
50	6.5
100	4.1
150	2.7

## Recommended K Values

Outlet Type	Discharge Pattern	K
High sidewall grille	0° deflection	5.0
High sidewall grille	wide deflection	3.7
High sidewall linear	core < 4" high	3.9
High sidewall linear	core > 4" high	4.4
Low sidewall	up wall, no spread	4.4
Low sidewall	wide spread	2.6
Baseboard	up wall, no spread	3.9
Baseboard	wide spread	1.8
Floor	no spread	4.1
Floor	wide spread	1.4
Ceiling circular	360°	1.0
Ceiling square	4-way, little spread	3.3
Ceiling square	1-way, little spread	4.4
Ceiling linear	1-way, horizontal	4.8

Life is never simple:

Most registers are rated at 75fpm throw boundary and tested at 100 plus cfm.




## Diffuser Comparisons

Room Designation	Throw Desired	CFM	Desired Selection VHO & HVO		Contractor Selection 6" x 10" & 6" x 12"		Generic Selection RZ682	
			Size	Throw	Size	Throw	Size	Throw
Laundry	4'	55	8 x 4	6.6'	6 x 10	3.6'	8 x 4	6.6'
Bedroom/Study	4.5'	110	8 x 4	13.3'	6 x 10	9.6'	6 x 10	9.1'
Family Rm	16'	142	10 x 4	15.8'	6 x 10	12.4'	6 x 10	9.1'
Family Rm	16'	142	10 x 4	15.8'	6 x 12	10.9'	6 x 10	9.1'
Mstr. Bath	7.5'	72	6 x 4	9.7'	6 x 10	6.3'	6 x 6	8.1'
Mstr. Bed	7.8'	142	10 x 4	12.3'	6 x 10	9.6'	8 x 8	11.2'
Office	7'	120	10 x 4	13.4	6 x 10	10.5'	12 x 4	11.5



# IBACOS


## 40% BA MIXED HUMID



## Diffuser Comparisons

Room Designation	Throw Desired	CFM	Desired Selection VHO & HVO		Contractor Selection 6" x 10" & 6" x 12"		Generic Selection RZ682	
			Size	Throw	Size	Throw	Size	Throw
Laundry	4'	55	8 x 4	6.6'	6 x 10	3.6'	8 x 4	6.6'
Bedroom/Study	4.5'	110	8 x 4	13.3'	6 x 10	9.6'	6 x 10	9.1'
Face Velocity			660		352		352	
Family Rm	16'	142	10 x 4	15.8'	6 x 10	12.4'	6 x 10	9.1'
Family Rm	16'	142	10 x 4	15.8'	6 x 12	10.9'	6 x 10	9.1'
Face Velocity			681		378		454	
Mstr. Bath	7.5'	72	6 x 4	9.7'	6 x 10	6.3'	6 x 6	8.1'
Mstr. Bed	7.8'	142	10 x 4	12.3'	6 x 10	9.6'	8 x 8	11.2'
Office	7'	120	10 x 4	13.4	6 x 10	10.5'	12 x 4	11.5


## Performance Characteristics of an 8x4 Adjustable Blade Diffuser (100 cfm)






# IBACOS

# DIFFUSER SELECTION AND DESIGN




FLOOR DIFFUSER


COOLING





SECTION A-A



HEATING



SECTION A-A




HIGH SIDEWALL

COOLING




SECTION A-A



HEATING





SECTION A-A







*With air entering at 95°F and 790 ft/min, the room has good mixing.*




Contours of deg-f (Time=1.7200e+02)


Mar 01, 2006  
FLUENT 6.2 (3d, segregated, rngke, unsteady)



*With air entering at 140°F and 330 ft/min, the room shows stratification.*



- Supply air Velocity
  - 394 f/m
  - 591 f/m
  - 787 f/m





- ***Equipment selection is critical***
- ***DO a duct design***
- ***Consider designing each duct run  
(Variable friction method – ASHRAE  
HVAC & Fundamentals Handbooks)***
- ***Supply outlets designed, not what's on  
the truck***
- ***Trending towards***
  - *Higher air velocity at outlet*
  - *Lower supply air temperature in heating mode*
  - *Longer run time*
  - *Be aware of air speed in occupied zone.*

***US DOE Building America Program  
Best Practices Research Alliance  
Cardinal Glass Industries  
Carrier Corporation  
National Renewable Energy Laboratory***



IBACOS

THANK YOU

**Questions?**

**dprahl@ibacos.com**

**astamatopoulos@ibacos.com**

