



# COSA

Carbon Monoxide Safety  
Association

*Erik Rasmussen*  
*(866) 408 8122*





# *Combustion & Carbon monoxide*





# *Air Required For Combustion*


- Primary
- Secondary
- Excess
- Dilution



# *Complete VS Incomplete*




# Manufacturer's Specifications



Atmospheric Forced Air

# Tests / Setup

- Fuel Pressure
- Draft
- Smoke Fuel oil
- Carbon Monoxide
- O<sub>2</sub> / Co<sub>2</sub> / Excess Air
- Draft / Smoke
- ESP / Delta T / etc...




90%  
Condensing  
gas

Oxygen  
reading  
7.5%





# *80%, Mid Efficiency, Fan Assist, Forced Air Furnaces*
















## Theoretical Air Curve / Natural Gas




*Measuring O<sub>2</sub> in combustion analysis provides greater precision in establishing the relationships of O<sub>2</sub>/ CO<sub>2</sub>/ Excess Air for accurate monitoring of burner performance.*





Customer Name Mary Jane Watson  
Location 999 Hillcrest Ave, Trenton  
Unit Identification # 1 York Mid Efficiency  
Burner Performance Documentation. Technician Name Fire Guy

Date 1/02/2002  
Time 1:31 PM  
Analyzer Serial # eu1107



Measured Combustion Test Results

Fuel Type NG / LPG	NG
Stack Temp °F	324
AMB Temp °F	74.4
Oxygen %	7.5
CO Air Free PPM	25
Efficiency %	82.4
Excess Air %	49.8
Breach Draft WC"	-.03
Over Fire Draft WC"	
Power Burners only	N/A

Additional information	
Temperature Rise °F	55
External Static Pressure	.5
Gas Pressure	3.5
Indoor Ambient CO Level PPM	0

Generally Acceptable Combustion Test Results  
Natural Gas Atmospheric Burners, Boilers, Mid EFF,  
Fan Assisted MID EFF and Condensing Units.

**Oxygen** (6% to 9%)

**Stack Temperature** (325°F to 500°F)

**Condensing Stack Temperature** (< 145°F)

**Carbon Monoxide Air Free** (Recommended to be  
Less Than 100 PPM Air Free) ANSI Standard < 400  
PPM AF

Generally Acceptable Combustion Test Results for  
Natural Gas Power Burners.

**Oxygen** (3% to 6%) units on Low Fire may have higher O<sub>2</sub>  
readings.

**Stack Temperature** (275°F to 500°F)

**Carbon Monoxide Air Free** (Recommended to be  
Less Than 100 PPM Air Free) ANSI Standard < 400  
PPM AF

(Always follow Manufacturers instructions  
PMI)

# *Combustion Efficiency*


Based on:

- How much energy is in the fuel.
- The net stack temperature
- The percentage of  $O_2$  or  $CO_2$  in the flue gases.

# Steady State Efficiency

Is only accurate when:

- O<sub>2</sub>, stack temperature and CO readings are within manufacturers specifications.
- The stack temperature has stabilized.



BACHARACH, INC.		
PCA 25		
*****		
TIME	04:40:35	PM
DATE	04/27/97	
FUEL		
OIL NO. 2		
STACK-TEMP	302	°F
AMB.-TEMP	59.5	°F
O2	5.8	%
CO2	11.3	%
CO	2	PPM
O% COR CO	2	PPM
EFFICIENCY	87.7	%
EX. AIR	35.61	
-----		
COMMENTS.....		

Printout of Combustion Test Results

SAVINGS FOR EVERY \$100 FUEL COSTS BY INCREASE OF COMBUSTION EFFICIENCY											
Assuming constant radiation and other unaccounted-for losses											
	From an original efficiency of..	To an increased combustion efficiency of...									
			55%	60%	65%	70%	75%	80%	85%	90%	95%
50%	\$9.10	\$16.10	\$23.10	\$28.60	\$33.30	\$37.50	\$41.20	\$44.40	\$47.40		
55%		\$8.30	\$15.40	\$21.50	\$26.70	\$31.20	\$35.30	\$38.90	\$42.10		
60%			\$7.70	\$14.30	\$20.00	\$25.00	\$29.40	\$33.30	\$37.80		
65%				\$7.10	\$13.30	\$18.80	\$23.50	\$27.80	\$37.80		
70%					\$6.70	\$12.50	\$17.60	\$22.20	\$26.30		
75%						\$6.30	\$11.80	\$16.70	\$21.10		
80%							\$5.90	\$11.10	\$15.80		
85%								\$5.60	\$10.50		